

Assessment for: KSR – Peter Vigue Center; ID ME0094850

Location: Eddington, Maine

Date: July 8, 2010

Summary of the Data used in our Assessment

Well type: Bedrock well

Well identification number: 94850101

Well description: Bedrock well; 205 ft deep

Overburden thickness (feet): 21 ft

Positive bacteria test result(s): No

Nitrate test result(s) greater than 5 ppm: No

Septic system(s) within 300 feet of the well: No

Animal feedlots/manure piles(s) within 300 feet of the well: No

Risk Based on Well Type and Site Geology

Ranking:

Well type: Bedrock well

Overburden thickness (feet): 21

*Existing risk of contamination
based on well type & site geology:*

Low risk

Existing Risk of Acute Contamination

Ranking:

Positive coliform test(s): No

Nitrate test(s) greater than 5 ppm: No

Septic system(s) within 300 feet of the well: No

Animal feedlot(s)/manure pile(s) within 300 feet of the well: No

Existing risk of acute contamination:

Low risk

Future Risk for Acute Contamination

Ranking:

Status of land control: The owner does own and control the land within the Well Head Protection Radius of 300 ft.

Future risk of acute contamination:

Low risk