

Assessment for: Enfield General Store, ME0094781

Location: Enfield, Maine

Date: August 26, 2009

Summary of the Data used in our Assessment

Well type: Bedrock well

Well identification number: 94781101

Well description: Bedrock well, drilled 105 ft

Overburden thickness (feet): 80 ft

Positive bacteria test result(s): No

Nitrate test result(s) greater than 5 ppm: No

Septic system(s) within 300 feet of the well: Yes

Animal feedlots/manure piles(s) within 300 feet of the well: No

Risk Based on Well Type and Site Geology

Ranking:

Well type: Bedrock well

Overburden thickness (feet): 80 ft

*Existing risk of contamination
based on well type & site geology:*

Low risk

Existing Risk of Acute Contamination

Ranking:

Positive coliform test(s): No

Nitrate test(s) greater than 5 ppm: No

Septic system(s) within 300 feet of the well: Yes

Animal feedlot(s)/manure pile(s) within 300 feet of the well: No

Existing risk of acute contamination:

Moderate risk

Future Risk for Acute Contamination

Ranking:

Status of land control: *The owner does not own or control the land within 300 ft of the well head protection radius.*

Future risk of acute contamination:

Moderate risk